



Certificate No.: 0502-H4940

Applicant for Certification: Taconova Group AG, Neunbrunnenstrasse 40, CH- 8050 Zürich

from: 10.12.2004

In accordance with our regulation ZW101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Mixing valves

Denomination: NovaMix High Capacity

Types: 252.6034.107

DN: 25 PN: - tmax= 90°C

Certification Standard: SGWA ZW 102/1 (07/15), ZW 102/2 (07/16),
UBA-Guideline, DIN 50930-6 (2001)

Validity: 30.06.2019

Notes / Conditions:

In the case of the thermostatic mixing valves, hygienic assessments have been carried out, for the components which come into contact with the drinking water, according to the KTW recommendations, UBA guidelines, the DVGW worksheet W 270 and DIN 50930-6 (edition 2001).

No tests were carried out on technical requirements, characteristics, functions and acoustics.

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).

Swiss Gas and Water Industry Association
Certification body water


Javier Fernandez
Head

Rubric: Mixing valves
Denomination: NovaMix High Capacity

Types	DN	PN	C°	Acoustic group	Losses	Content Index	Metrological class
NovaMix High Capacity							
252.6034.107	25	-	90				
