



Certificate No.: 1602-H6471

Applicant for Certification: Taconova Group AG, Neunbrunnenstrasse 40, CH- 8050 Zürich

from: 27.01.2016

In accordance with our regulation ZW101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Hot water circulation
Denomination: Balancing valve, typeTacoSetter Hyline
Types: 223.8410.000, DN 25
223.8411.000, DN 25
223.8412.000, DN 25
223.8523.000, DN 32
223.8524.000, DN 32

DN: 25, 32 PN: - tmax= 25 / 80°C

Certification Standard: SGWA ZW 102/1 (01/16), ZW 102/2 (01/16), UBA-Guideline

Validity: 31.05.2021

Notes / Conditions:

Only the hygienic assessment (LTW-recommendation, DVGW-Workshett W 270, WRAS and CAS) of the components from the balancing valves, which come into contact with drinking water, was examined. It carried out no checks to technical requirements, features, functions and acoustic.

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).



accredited according to
SN EN ISO/IEC 17065

Swiss Gas and Water Industry Association
Certification body water


Javier Fernandez
Head

Rubric: Hot water circulation

Denomination: Balancing valve, type TacoSetter Hyline

Types	DN	PN	C°	Acoustic group	Losses	Content Index	Metrological class
223.8410.000	25	-	25 / 80			9	
223.8411.000	25	-	25 / 80			9	
223.8412.000	25	-	25 / 80			9	
223.8523.000	32	-	25 / 80			9	
223.8524.000	32	-	25 / 80			9	