



The undersigned (customer) confirms receipt of the drawing in hand and is herewith informed of the required dimensions for optimal operation of the Topmeter. The customer is responsible for the compliance with all functionally relevant dimensions of the manifold and the lower valve body.

*) The responsibility for the sealing between manifold and Topmeter lies with the customer and has to be implemented as serviceable connection. Adhesives and sealing compounds are regarded as unsuitable.

Company:

Date:

Name:

Visa:

Leak test, max. allowed values	
Testing pressure (air / water)	10 bar
Room- / Medium temperature	5 to 35°C

Artikel - Nr.		Benennung		Zeichnungs-Nr.	
l		Toleranzen ISO 2768	Massstab:	Material:	
k		f m c	2:1	Volumen / Gewicht:	
i				Ersatz für:	
h		Oberflächen / Surfaces	☉	Techn. Lieferbed.:	
g		DIN-ISO 1302		Ersetzt durch:	
f		Datum	Visum	Collector of heating circuit with balancer of A023	
e	2500	10.08.07	sc	Fitting dimensions	
d	2448	13.02.07	RV	Flow Pipe Topmeter 1/2"	
c	2414	18.10.06	sc	A3 3-5332 english e	
b	2183	09.11.04	sc	Blatt-Nr. 1	
a	2113	23.07.03	RV	Anz. Blatt 1	
	2013	22.11.02	RV		
Index	EM	Datum	Visum		
		☉ STACO AG			
		CH-8902 Urdorf			
Für dieses Dokument behalten wir uns alle Rechte vor.		Nous nous réservons tout les droits sur ce document.		We reserve all rights in connection with this document.	