



The undersigned (customer) confirms receipt of the drawing in hand and is herewith informed of the required dimensions for optimal operation of the Topmeter. The customer is responsible for the compliance with all functionally relevant dimensions of the manifold and the lower valve body.

*) The responsibility for the sealing between manifold and Topmeter lies with the customer and has to be implemented as serviceable connection. Adhesives and sealing compounds are regarded as unsuitable.

Company:

Date:

Name:

Visa:

Artikel - Nr.		Benennung		Zeichnungs-Nr.	
l		Toleranzen ISO 2768		Massstab:	Material:
k		f	m	c	2:1
i		Oberflächen / Surfaces DIN-ISO 1302		Gez.	15.04.97
h		Datum		Visum	SCH
g		10.08.07		F. Stähli	
f		10.08.07		D. Gunttern	
e		10.08.07		D. Gunttern	
d	2500	10.08.07	sc	Collector of heating circuit with balancer of A023	
c	2183	09.11.04	sc	Fitting dimensions	
b	1581	14.01.98	FS	Return Pipe Topmeter 3/8"	
a	1244	15.04.97	SCH	©STACO AG	
Index	EM	Datum	Visum	CH-8902 Urdorf	
Für dieses Dokument behalten wir uns alle Rechte vor.		Nous nous réservons tout les droits sur ce document.		We reserve all rights in connection with this document.	
A3 3-4895 english				c	Blatt-Nr. 1
					Anz. Blatt 1