



The undersigned (customer) confirms receipt of the drawing in hand and is herewith informed of the required dimensions for optimal operation of the Topmeter. The customer is responsible for the compliance with all functionally relevant dimensions of the manifold and the lower valve body.

\*) The responsibility for the sealing between manifold and Topmeter lies with the customer and has to be implemented as serviceable connection. Adhesives and sealing compounds are regarded as unsuitable.

Company:

Date:

Name:

Visa:

Artikel - Nr.		Benennung				Zeichnungs-Nr.	
l		Toleranzen ISO 2768		Massstab:	Material:		
k		f	m	c	2:1	Volumen / Gewicht:	
i		Oberflächen / Surfaces DIN-ISO 1302		Techn. Lieferbed.:			
h		Datum		Visum	Ersatz für:		
g		14.06.96		SM	Ersetzt durch:		
f		10.08.07		F. Stähli	Collector of heating circuit with balancer AO 23		
e		10.08.07		D. Gunttern	Fitting dimensions		
d	2500	10.08.07	sc	Return Pipe Topmeter 1/2"			
c	2183	09.11.04	sc	A3 3-4830 english d			
b	1581	15.01.99	FS	Blatt-Nr. 1			
a	1311	18.07.97	zi	Anz. Blatt 1			
		14.06.96	SM				
Index	EM	Datum	Visum				
© STACO AG		CH-8902 Urdorf					
Für dieses Dokument behalten wir uns alle Rechte vor.		Nous nous reservons tout les droits sur ce document.		We reserve all rights in connection with this document.			